

Safety Integrity Level [S.I.L.] Declaration

In accordance with ISO / IEC 17050-1:2004

independently assessed and found to conform to the requirements of IEC 61508:2005. We the undersigned declare under our sole responsibility that the product to which this declaration relates have been

respect of Safe Failure Fraction (SFF) the unit has been judged to be suitable for use, as specified below: Conformity has been derived from a combination of failure mode and effect analysis [FMEA] and proven in use returns data, in

Reference No / Version

SIL 13-001

Product Description

Xgard Type 5, Type 6 and Xgard IR

Specific Standards

IEC61508

Safety Manner: Simplex

Assessment Results

Xgard Type 5 (Pellistor type sensor)

1	1	1	1.1	Total Failure Rate
ı		1	0.05	Spurious indication of a high gas level
2	67	8.010^{-4}	Н	Failure to respond to high gas level
S.I.L.	SFF ³ %	PFD ²	Failure Rate ¹	

Xgard Type 6 (Thermal Conductivity type sensor)

1	1	1	1.1	Total Failure Rate
ı	ı	ı	0.4	Spurious indication of a high gas level
ω	95	$1.1 10^{-4}$	0.35	Failure to respond to high gas level
S.I.L.	SFF ³ %	PFD ²	Failure Rate ¹	

Xgard IR (Infrared type sensor)

§	Failure Rate ¹	PFD ²	SFF ³ %	S.I.L.
Failure to respond to high gas level	0.7	$1.3 \ 10^{-4}$	95	2
Spurious indication of a high gas level	0.05	1	-	ı
Total Failure Rate	1.1	1	-	1

Crowcon Detection Instruments Ltd

Abingdon, Oxfordshire, OX14 1DY 2 Blacklands Way, Abingdon Business Park



BPD - T - 21359 Ver 01.01

^{2. -} Probability of Failure on Demand3. - Safe Failure Faction



Assessment Body

Technis

26 Orchard Drive

Tonbridge, Kent TN10 4LG

Report number: T387 Issue 2.0 Issue date: 9th Nov 2012

Signature: Signatory

Mark Osborne, Product Development Director

Date:

Name & Position:

7th July 2013

1. - Per Million Hours
2. - Probability of Failure on Demand
3. - Safe Failure Faction

2 Blacklands Way, Abingdon Business Park **Crowcon Detection Instruments Ltd** Abingdon, Oxfordshire, OX14 1DY WEB SITE www.crowcon.com United Kingdom

